

To: INTERESTED PARTIES
From: ICC- EVALUATION SERVICE AND PLASTIC PIPE AND FITTINGS ASSOCIATION
Date: DECEMBER 18, 2018
Subject: COMMENTS AND RESPONSE TO PUBLIC COMMENTS OF PRODUCT CATEGORY RULES (PCR) FOR PREPARING AN ENVIRONMENTAL PRODUCT DECLARATION (EPD) FOR: RIGID AND FLEXIBLE BUILDING PIPING SYSTEMS IN NORTH AMERICA

The PCR for preparing an EPD for: Rigid and Flexible Building Piping Systems in North America has been approved by ICC-ES and PPFA.

Comments received from interested parties during the 30 day public review, dated October 30th, 2018, is as follows:

1. Page 3 – the ICC-ES link to the “PCR peer review report” is broken
2. Page 4 – the link at the bottom of the page (ec.europa.eu) is broken
3. Page 22 – the link to Davis Energy is broken
4. Page 24 – the bottom of the page says “Error! Reference source not found...”, which I think is supposed to say “Table 5”
5. Why was ASTM D2729 excluded from the Polyvinyl Chloride Section of Table 3 of the PCR?

Comments 1-5 are from Silver-Line Plastics

Our response to the comments above is as follows:

1. Replaced with correct and updated URL
 2. Replaced with correct and updated URL
 3. Replaced with correct and updated URL
 4. Corrected Error message to read table 5
 5. Was an oversight to exclude ASTM D2729, and the PCR has been revised to include it.
- 