

Laurie Spandle

From: Chris LaVine <clavine@strongtie.com>
Sent: Tuesday, September 8, 2020 2:23 PM
To: es
Cc: Howard Silverman; Marlou B. Rodriguez
Subject: Comments on the Proposed Revisions to the Acceptance Criteria for Adhesive Anchors in Cracked and Uncracked Masonry Elements, Subject AC58-1020-R1 (HS/VC)

Dear Mr. Silverman,

Simpson Strong-Tie company has reviewed the Proposed Revisions to the Acceptance Criteria for Adhesive Anchors in Cracked and Uncracked Masonry Elements, Subject AC58-1020-R1 (HS/VC) dated August 18, 2020. We find all of the changes made to be acceptable. However, there is one change that was recommended in the CAMA letter dated June 12, 2020 that has not been included.

A change to Table 4.4 was recommended in the CAMA letter, based on the changes made to sections 7.4.1.1 and 7.5.1.1. That change was to remove the footnote reference to Test No. 6a and Test No. 6b. Since these tests are required as detailed in sections 7.4.1.1 and 7.5.1.1, the superscript “§” noted in the Test No. column of Table 4.4 for Test No. 6a and Test 6b should be removed.

Please let us know if you have any questions.

Chris La Vine | **Simpson Strong-Tie Company**
Senior Engineer - Concrete Construction Products
2505 Enterprise Circle, West Chicago, IL 60185
(630) 293-2813 clavine@strongtie.com