



ICC Evaluation Service, LLC
Western Regional Office
3060 Saturn Street, Suite 100
Brea, CA 92821
t: 1.800.423.6587, ext. 1
f: 562.695.4694
www.icc-es.org

To: ICC-ES Evaluation Committee
From: Mahmut Ekenel, Vincent Chui
Date: October 2, 2020
Subject: Proposed Acceptance Criteria for CO₂Concrete-Based Concrete Masonry Units, AC520-1020-R1 (ME/VC)

MEMO

ICC-ES staff would like to make a minor editorial change to AC520-1020-R1, which was posted on the ICC-ES website on August 18, 2020. The minor editorial change is outlined below:

Sections 1.3.14 and 1.3.20, and their references to ASTM E84 and UL 723, are being deleted. Since the surface burning characteristics of concrete masonry units (CMU) are not in question, the ICC-ES staff is proposing to remove references to these test standards from Section 1.3.

A decorative graphic at the bottom of the page consisting of several overlapping, wavy lines in shades of green, creating a modern, organic shape.