



## ICC-ES Listing Report

Reissued July 2024

### ESL-1022

This listing is subject to renewal July 2025.

**CSI:** DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION  
Section: 07 25 00—Water-Resistive Barriers/Weather Barriers

#### Product Certification System:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

**Product:** TAMLYNWRAP™ HOUSEWRAP

**Listee:** R.H. TAMLYN & SONS LP

**Evaluation:** The TamlynWrap™ Housewrap, was evaluated based on testing to the following standards:

- UL 723-2008 and -03, Tests for Surface Burning Characteristics of Building Materials
- ASTM E84-09 and -07, Standard Test Method for Surface Burning Characteristics of Building Materials

**Findings:** The TamlynWrap™ Housewrap has a flame spread index of 25 or less, and smoke developed index of 450 or less, per UL723/ASTM E84.

#### Identification:

1. Each roll of the TamlynWrap™ Housewrap is identified with a label indicating the manufacturer's name, logo and website address, the product name and the listing number (ESL-1022) and/or the ICC-ES evaluation report number (ESR-3670).
2. The report holder's contact information is the following:

R.H. TAMLYN & SONS LP  
13623 PIKE ROAD  
STAFFORD, TEXAS 77477-5103  
(281) 499-9604  
(800) 384-1676  
[www.tamlynwrap.com](http://www.tamlynwrap.com)

**Installation:** The product must be installed in accordance with the R.H. Tamlyn & Sons instructions.

#### Conditions of listing:

1. The listing addresses only conformance with the standards and code sections noted above. Additional information can be found in ICC-ES evaluation report [ESR-3670](#).
2. Approval of the product's use is the sole responsibility of the local code official.