





www.icc-es.org | (800) 423-6587 | (562) 699-0543

ICC-ES Listing Report ESL-1213

A Subsidiary of the International Code Council®

Reissued March 2025 This listing is subject to renewal March 2026.

CSI: DIVISION: 09 00 00–FINISHES Section: 09 96 43–Fire-Retardant Coatings

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: FIREFREE 88[®] (FF88[®]) AND FIREFREE[®] CLASS A (FfA) FIRE-RETARDANT COATINGS

Listee: FIREFREE COATINGS, INC.

- **Evaluation:** FireFree 88[®] (FF88[®]) and FireFree[®] Class A (FfA) Fire-Retardant Coatings, when applied to a exposed surfaces of unfished Douglas Fir dimensional lumber or oriented strand board (OSB) at a minimum coverage rate of 3.07 m²/L (125 square feet per gallon), were evaluated when tested to the following standard: was evaluated when tested to the following standard:
 - CAN/ULC-S102-10 and CAN/ULC-S102-07, Standard Method of Test for Surface Burning Characteristics for Building Materials and Assemblies, Underwriters Laboratories, Inc.
- **Findings:** FireFree 88[®] (FF88[®]) and FireFree[®] Class A (FfA) Fire-Retardant Coatings has a flame-spread index and a smoke-developed index as specified in Table 1 below based on testing in accordance with CAN/ULC-S102, as referenced in the applicable sections of the following code editions below:

PRODUCT	FLAME-SPREAD INDEX (FSI)	SMOKE- DEVELOPED INDEX (SDI)
³ / ₄ inch OSB	10	75
Nominal 2 X 6 Douglass Fir sawn lumber	10	90

TABLE 1–FLAME SPREAD INDEX AND SMOKE DEVELOPED INDEX

- National Building Code of Canada[®] 2015 Applicable Section: Volume 1, Division B, Section 3.1.12.
- National Building Code of Canada 2010[®] Applicable Section: Volume 2, Division B, Section 3.1.12.

Identification:

1. Containers of FireFree 88[®] (FF88[®]) and FireFree[®] Class A (FfA) fire retardant coatings is identified by the label bearing the manufacturer's name (FireFree Coatings, Inc.) and address, the product name, the date of manufacture, shelf life, the manufacturer's instructions for application, the ICC-ES Listing report number (ESL-1213), and the ICC-ES Listing Mark.

Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.



2. The report holder's contact information is the following:

FIREFREE COATINGS, INC. 8 COMMERCIAL BOULEVARD, SUITE E NOVATO, CALIFORNIA 94949 (415) 459-6488 www.firefree.com info@firefree.com

Installation: The product must be installed in accordance with the FireeFree Coatings, Inc.'s published installation instructions and applicable codes.

Conditions of listing:

- 1. The listing report addresses only conformance with the standard noted above.
- 2. Approval of the product's use is the sole responsibility of the local code official.
- 3. The listing report applies only to the product tested and as submitted for review by ICC-ES.
- 4. FireFree 88[®] (FF88[®]) fire-retardant coating is produced under a quality control program with inspections by ICC-ES.