



ICC-ES Listing Report

ESL-1294

Reissued June 2024

This listing is subject to renewal December 2024.

CSI: DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 25 00—Water-resistive Barriers/Weather Barriers

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee’s quality system.

Product: WRAPTITE™ WEATHER RESISTIVE BARRIER

Listee: A PROCTOR GROUP LTD.

Evaluation: Wraptite™ weather resistive barrier is a spun-bonded, nonperforated, polypropylene material with a nominal thickness of 0.023 inch and a basis weight of 5.01 ounces per square yard (170 g/m²). The membrane is available in rolls, where the color of the exterior surface is orange-brown and the color of the unexposed surface is white. The membrane was evaluated when tested in accordance to the following standard:

- ASTM E84-18 and ASTM E84-16, Standard Test Method for Surface Burning Characteristics of Building Materials, ASTM International.

Findings: Wraptite™ weather resistive barrier have a flame-spread index and smoke-developed index as specified in Table 1 (Class A) below based on testing in accordance with ASTM E84, as referenced in the applicable sections of the following code editions below.

TABLE 1—FLAME-SPREAD INDEX AND SMOKE-DEVELOPED INDEX

PRODUCT	FLAME-SPREAD INDEX (FSI)	SMOKE-DEVELOPED INDEX (SDI)
Wraptite™	0	10

- 2021 and 2018 *International Building Code*®
Applicable Section: 803.1.2
- 2021 and 2018 *International Residential Code*®
Applicable Section: R302.9

Identification:

1. The Wraptite™ membrane described in this report is identified by a label, on the wrapper of each roll of membrane, bearing the manufacturer’s name (A Proctor Group), the product name, the manufacturing location (Forfar, Angus, Scotland), the ICC-ES evaluation report number (ESR-1916) and/or ICC-ES listing number (ESL-1294), and when applicable, the ICC-ES listing mark.

2. The report holder's contact information is the following:

**A PROCTOR GROUP LTD.
THE HAUGH, BLAIRGOWRIE
PERTSHIRE, SCOTLAND, PH10 7ER
UNITED KINGDOM
(44) 1250 87 2261
www.proctorgroup.com
technical@proctorgroup.com**

Installation: The product must be installed in accordance with A Proctor Group Ltd.'s published installation instructions and applicable codes.

Conditions of Listing:

1. The listing report addresses only conformance with the standard and code sections noted above.
2. Approval of the product's use is the sole responsibility of the local code official.
3. The listing report applies only to the materials tested and as submitted for review by ICC-ES.
4. The Wraptite™ weather resistive barrier is manufactured under a quality control program with inspections by ICC-ES.