



ICC-ES Listing Report ESL-1386

Reissued November 2024

This listing is subject to renewal November 2025.

CSI: DIVISION: 09 00 00—FINISHES
Section: 09 77 00—Special Wall Surfacing

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: DRICORE SMARTWALL

Listee: AGT PRODUCTS INC.

Evaluation: The DRICORE® SMARTWALL® panel was evaluated when tested to the following standards:

- ASTM E84-13, Standard Test Method for Surface Burning Characteristics of Building Materials, ASTM International.
- UL 723-2008 (revisions through September 2010), Standard for Test for Surface Burning Characteristics for Building Materials, Underwriters Laboratories, LLC

Findings: The DRICORE® SMARTWALL® panel has a flame-spread index of 25 or less and a smoke-developed index of 450 or less, based on testing in accordance with ASTM E84/UL 723, as referenced in the applicable sections of the following code editions:

- 2015 *International Residential Code*®
Applicable Section: R316

Identification:

1. Packaging of the DRICORE® SMARTWALL® carries a label indicating the manufacturer's name and address, the product name, a statement "For Use in One- and Two-Family Dwellings Only" and the ICC-ES Evaluation Report number (ESR-3790) and/or ICC-ES Listing Report number (ESL-1386), and when applicable, the ICC-ES Listing Mark.
2. The report holder's contact information is the following:

AGT PRODUCTS INC.
2311 ROYAL WINDSOR DRIVE, UNIT 2
MISSISSAUGA, ONTARIO L5J 1K5
CANADA
(905) 491-3883
www.dricore.com
clayton.fearon@dricore.com

Installation: The system/product must be installed in accordance with the AGT Products, Inc. published installation instructions and applicable codes.

Conditions of listing:

1. Additional attributes and their applications can be found in the ICC-ES Evaluation Report, ESR-3790.
2. The listing report addresses only conformance with the standards and code section noted above.
3. Approval of the product's use is the sole responsibility of the local code official.
4. The listing report applies only to the materials tested and as submitted for review by ICC-ES.