



ICC-ES Listing Report

ESL-1415

Reissued July 2024

Revised August 2024

This listing is subject to renewal July 2025.

CSI: DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 54 19—Polyvinyl-Chloride Roofing

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: C3 Plus (60 mil)

Listee: COOLEY, INC.

Evaluation: C3 Plus (60 mil) is a single-ply polyvinyl chloride (PVC) roofing membrane. The membrane was evaluated when tested at a thickness of 60 mil (1.52 mm) to the following standard:

- CAN/ULC-S102.2 (-2018 and 2010), Standard Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies, Underwriters Laboratories of Canada

Findings: C3 Plus (60 mil) has a flame-spread rating of 55 and a smoke-developed classification of 395, when tested in accordance with CAN/ULC-S102.2, as referenced in the applicable section of the following code editions:

- *National Building Code of Canada*® 2020 and 2015
Applicable Section: Volume 1, Division B, Section 3.1.12.1.(2)(c)

Identification:

1. The ICC-ES mark of conformity, electronic labeling, or the listing report number (ICC-ES ESL-1415), and when applicable, the ICC-ES listing mark, along with the name, registered trademark, or registered logo of the report holder must be included in the product label.
2. In addition, each roll of C3 Plus (60 mil) roofing membrane has a label bearing the manufacturer's name (Cooley, Inc.) and the product name
3. The report holder's contact information is the following:

COOLEY, INC.
350 ESTEN AVENUE
PAWTUCKET, RHODE ISLAND 02860
(401) 724-9000
www.cooleysgroup.com

Installation: The product must be installed in accordance with the Cooley, Inc.'s published installation instructions and applicable codes.

Conditions of listing:

1. The listing addresses only conformance with the standards and code sections noted above.
2. Approval of the product's use is the sole responsibility of the local code official.
3. The listing applies only to the material tested and as submitted for review by ICC-ES.
4. The C3 Plus (60 mil) roofing membrane is manufactured in under a quality control program with inspections by ICC-ES.