



CSI: DIVISION: 09 00 00–FINISHES
Section: 09 00 00–Finishes

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: VIPEQ® F08 THERMAL CORKSHIELD

Listee: VIPEQ HISPANIA 2008 SL

Evaluation: VIPEQ® F08 Thermal Corkshield is a two component spray-applied coating comprised of cork particles with a proprietary blend of resin, mineral filler and colorant that is mixed and dispensed from a dispensing system provided by Vipeq Hispania 2008L. The coating is available in a wide range of colors. The coating is available in 12 kg pails, each with a shelf-life of one year in tightly closed containers when stored at temperatures of 28.4°F to 113°F (-2°C to 45°C). The product was evaluated to the following standard:

- CAN/ULC-S102-10, Standard Method of Test for Surface Burning Characteristic of Building Material and Assemblies, Underwriters Laboratories of Canada.

Findings: Vipeq F08 Thermal Corkshield, has a flame spread rating of 0 and has a smoke developed classification of 10, when tested in accordance with CAN/ULC-S102, as referenced in the applicable sections of the following code editions:

- *National Building Code of Canada*® 2020
Applicable Section: Volume 1, Division B, Section 3 1.12.
- *National Building Code of Canada*® 2015
Applicable Section: Volume 1, Division B, Section 3.1.12.

Identification:

1. The ICC-ES mark of conformity, electronic labeling, or the listing report number (ICC-ES ESL-1538), and when applicable, the ICC-ES listing mark, along with the name, registered trademark, or registered logo of the listee must be included in the product label.
2. In addition, packages of VIPEQ® F08 Thermal Corkshield described in this report are identified by a label bearing the report holder's name (Vipeq Hispania 2008L) and address, product name, color, date of manufacture, and production batch number).
3. The report holder's contact information is the following:

VIPEQ HISPANIA 2008 SL
PARQUE EMPRESARIAL LA ESTRELLA 1
c/BERROA 2 OF 110 2
TAJONAR, NAVARRA 31192
SPAIN
+34948852295
www.vipeq.eu, infotech@vipeq.es

Installation: The product must be installed in accordance with the VIPEQ Hispania 2008 SL's published installation instructions and applicable codes.

Conditions of listing:

1. The listing addresses only conformance with the standards and code sections noted above.
2. Approval of the product's use is the sole responsibility of the local code official.
3. The listing applies only to the materials tested and as submitted for review by ICC-ES.
4. VIPEQ F08 Thermal Corkshield is manufactured in Mississauga, Ontario, Canada and Beriain, Spain under a quality control program with inspections by ICC-ES.