



ICC-ES Listing Report ESL-1590

Reissued October 2024

This listing is subject to renewal in October 2025.

CSI: DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION
Section: 07 46 00 – Siding
Section: 07 42 93 – Linear Metal Soffits

Product Certification System:

The ICC-ES product-certification system includes evaluating reports of tests of standard manufactured product, prepared by accredited testing laboratories and provided by the listee, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the listee's quality system.

Product: LONGBOARD SIDING

Listee: LONGBOARD ARCHITECTURAL PRODUCTS INC

Evaluation: Longboard Siding is available in three profiles; V-Groove, Channel and Smooth; lengths up to 24 feet (7.3 m); and is 1/16 inch (1.59 mm) thick. It is fabricated from aluminum conforming to 6063 T5 and has a powder coating. Each profile is additionally available with or without a continuous rib (L-Rib or T-Rib) that runs along the center of the panel. It was evaluated based on testing in accordance with the following standards:

- ASTM E136-2019 – Standard Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750°C.

Findings: Longboard Siding is classified as a non-combustible building construction material, based on testing in accordance with ASTM E136, as referenced in the applicable sections of the following code editions.

- 2021 *International Building Code*®
Applicable Section: 703.3.1
- 2021 *International Residential Code*®
Applicable Section: R202

Identification:

1. The ICC-ES mark of conformity, electronic labeling, or the listing report number (ICC-ES ESL-1590), and when applicable, the ICC-ES Listing Mark, along with the name, registered trademark, or registered logo of the listee must be included in the product label.
2. In addition, each bundle of siding is marked with the report holder's name and the profile number.
3. The report holder's contact information is the following:

LONGBOARD ARCHITECTURAL PRODUCTS INC
#120-1777 CLEARBROOK ROAD
ABBOTSFORD, BRITISH COLUMBIA V2T 5X5
CANADA
(604) 607-6630
www.longboardproducts.com
info@longboardproducts.com

Installation: Longboard Siding must be installed in accordance with the Longboard Architectural Products Inc. published installation instructions and applicable codes.

Conditions of listing:

1. Additional attributes and their application can be found in the ICC-ES Evaluation Report, ESR-4182.
2. The listing addresses only conformance with the standards and code sections noted above.
3. Approval of the product's use is the sole responsibility of the local code official.
4. The listing applies only to the materials tested and as submitted for review by ICC-ES.
5. Longboard Siding is manufactured under a quality control system with inspections by ICC-ES.