

ICC-ES Evaluation Report

ESR-2229

Reissued May 2024

This report also contains:


- CBC Supplement

Subject to renewal May 2025

- FBC Supplement

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

Copyright © 2024 ICC Evaluation Service, LLC. All rights reserved.

<p>DIVISION: 07 00 00— THERMAL AND MOISTURE PROTECTION</p> <p>Section: 07 40 00— Roofing and Siding Panels</p>	<p>REPORT HOLDER:</p> <p>FOUR SEASONS BUILDING PRODUCTS, LLC</p>	<p>EVALUATION SUBJECT:</p> <p>LAMINATED FOAM ROOF AND NPW-I WALL PANELS</p>	
--	--	---	---

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2021, 2018, 2015, 2012 and 2009 [International Building Code® \(IBC\)](#)
- 2021, 2018, 2015, 2012 and 2009 [International Residential Code® \(IRC\)](#)

Properties evaluated:

- Structural
- Roof classification

2.0 USES

The Four Seasons Building Products, LLC, laminated foam roof panels are used as structural roof panels of patio covers complying with Appendix I of the IBC and Appendix AH of the 2021 IRC (Appendix H of the 2018, 2015, 2012 and 2009 IRC). The NPW-I wall panels are nonload-bearing panels used as the full-height wall and kneewall panels of patio enclosures regulated by Appendix I of the IBC and Appendix AH of the IRC (Appendix H of the 2018, 2015, 2012 and 2009 IRC).

3.0 DESCRIPTION

3.1 General:

3.1.1 Laminated Foam Roof Panels: The Four Seasons Building Products, LLC, laminated foam roof panels are factory-laminated sandwich panels consisting of aluminum facing on both sides of a foam plastic core. The panels have nominal thicknesses of 3, 3.5, 4 and 6 inches (76, 89, 101 or 152 mm), are 48 inches wide (1219 mm), and have a maximum length of 30 feet (9.1 m). As an option, the panels may include an internal aluminum channel beam, factory-installed parallel to the length of the panel and centered on the panel width. The panels have a tongue-and-groove configuration at the sides.

3.1.2 NPW-I Wall Panels: The NPW-I wall panels are factory-laminated panels consisting of an exterior facing of tempered, prefinished, hardboard; a foam plastic core; and an interior facing of lauan plywood. The panels have square-cut edges and a nominal overall thickness of 2 to 3 inches (51 to 76 mm).

3.2 Material:

3.2.1 Laminated Foam Roof Panels:

3.2.1.1 Panel Core: The core material is either a 1.0 pcf (16.02 kg/m³) nominal density, Type I or 1.5 pcf (24.0 kg/m³) nominal density, Type II, expanded polystyrene (EPS) foam plastic board complying with ASTM C578. The board is supplied by the manufacturer identified in the approved quality documentation. The foam

plastic has a flame-spread index of 25 or less and a maximum smoke-developed index of 450 when tested in accordance with ASTM E84.

3.2.1.2 Panel Facings: The aluminum facing material of the panels with 1.5 pcf EPS board is 3105-H14 aluminum with a nominal thickness of either 0.024 inch (0.61 mm) or 0.032 inch (0.81 mm), having a minimum base-metal thickness of 0.022 or 0.028 inch (0.56 or 0.71 mm), respectively. The minimum tensile and yield strengths of the panel facings are 25 ksi (172 MPa) and 21.5 ksi (148 MPa), respectively.

The aluminum facing material of the panels with 1.0 pcf EPS board is 3105-H254 aluminum with a nominal thickness of 0.024 inch (0.61 mm), having a minimum base-metal thickness of 0.022 inch (0.56 mm). The minimum tensile and yield strengths of the panel facings are 23.5 ksi (162 MPa) and 19.5 ksi (134 MPa), respectively.

3.2.1.3 Panel Adhesive: The aluminum facings are factory-laminated to the panel core with an adhesive, described in the approved quality documentation that is a Type II, Class 2, adhesive complying with the ICC-ES Acceptance Criteria for Sandwich Panel Adhesives (AC05).

3.2.1.4 Fasteners: Fasteners used to attach the panels to underlying supports must be 1/4-inch-diameter (6.4 mm) nominal screw size, cadmium plated, steel tapping screws installed with a 1-inch-outside-diameter (25.4 mm), cadmium plated steel washer and a neoprene insert. Maximum fastener spacing must be limited to 12 inches (304.8 mm). Length of fastener must be at least 1 inch (25.4 mm) longer than the roof panel thickness. The fastener's allowable pull-through capacity is 70 lbs based on connection test data and a safety factor of 3.0.

3.2.1.5 Channel Beams: The channel beam is a 1-by-3-inch (25.4 mm by 76 mm) extruded aluminum rectangular tube of alloy and temper 6063-T6 with a nominal wall thickness of 0.060 inch (1.52 mm). The channel beam is factory-installed in the panels by creating a slot to insert the channel beam by removing from the core a piece of foam plastic measuring 1.5 inches deep by 3 inches wide (38 by 76 mm). The slot is located 1/2 inch (12.7 mm) from the interior face of the panel. The channel beam is inserted into the slot and a piece of 1/2-inch-thick (12.7 mm) EPS foam is placed in the gap between the skin and the beam.

3.2.2 NPW-I Wall Panels:

3.2.2.1 Exterior Face: The exterior facing is 1/8-inch-thick (3.2 mm), tempered, prefinished hardboard panels described in the quality documentation.

3.2.2.2 Interior Face: The interior facing is prefinished 1/8- to 1/4-inch-thick (3.2 to 6.4 mm) lauan plywood complying with ANSI/HP-1983. Lauan plywood panels are labeled by the Hardwood Plywood and Veneer Association (HPVA) (TL-224).

3.2.2.3 Core: The panel core must be 2-or 3-inch-thick (51 or 76 mm), RMAX TSX8500, which must be 2 pcf (32 kg/m³) polyisocyanurate foam plastic board complying with ASTM C1289.

3.2.2.4 Adhesive: The facings are bonded to the foam plastic core with an adhesive described in the approved quality documentation and complying with AC05, as a Type II, Class 2, adhesive.

4.0 DESIGN AND INSTALLATION

4.1 Design:

4.1.1 Laminated Foam Roof Panels: For use in allowable stress design, the allowable uniform gravity, downward and upward wind loads for the panels used as roof panels are as set forth in [Table 1](#) for panels with 1.5 pcf EPS core, and [Table 2](#) for panels with 1.0 pcf EPS core. The tabulated loads are the allowable total transverse loads for the roof panels, which require that the connections between panels and supports comply with Section 4.2.1 of this evaluation report, and must be greater than the applied loads determined in accordance with the code, including the load combinations in IBC Section 1605. As permitted by Section 4.2.1 of this evaluation report, panel to support connections may use fasteners described in Section 3.2.1.4, provided an engineering design by a registered design professional is submitted to code official for approval, and the engineering design must consider all applicable limit states, such as pull-over strength as described in Section 3.2.1.4, and screw strength and screw pull-out strength, which are outside the scope of this evaluation report. Use of the panels to resist any other load conditions (such as axial compression or tension forces due to horizontal wind loads or use as a roof diaphragm to resist seismic or horizontal-wind loads) is outside the scope of this report.

4.1.2 NPW-I Wall Panels: The panels have an allowable positive and negative transverse (wind) load of 25 psf (1197 Pa) for panels installed with a 48-inch (1219 mm) horizontal span between supporting patio enclosure mullions or posts. Use of the panels to resist any other load conditions (such as axial compression or tension forces due to gravity and wind loads, or use as a shear wall to resist seismic or horizontal-wind loads) is outside the scope of this report.

4.2 Installation:

4.2.1 Laminated Foam Roof Panels: The panels must be installed as the roof of the patio cover with the panel length continuous in the direction of the roof slope, without transverse joints. The roof panel longitudinal seam must be located a minimum of 23 inches (584 mm) from the inside face of the wall parallel to the panel length. A thermal barrier as specified by the code is not required to be installed in the interior of the patio cover structure. The panels must be installed with a roof slope as indicated in [Tables 1](#) and [2](#). Supports at each end of the panel span must provide the panels with a minimum 1-inch-wide (25.4 mm) continuous bearing width, to provide support for panels subjected to gravity loads, and upward and downward wind loads. As an alternative to restraining the panels subjected to wind uplift loads, the panels must be fastened using fasteners described in Section 3.2.1.4 and the fastener connection design must comply with requirements in Section 4.1.1 of this report. The installation details must be submitted to the code official for approval.

4.2.2 Roof Classification: The laminated foam roof panels have a Class B roof classification in accordance with ASTM E108. The maximum roof slope must not exceed 1:12 (8.3 percent). For recognition under the IRC as a nonclassified roof covering the maximum roof slope limitation is not applicable.

4.2.3 NPW-I Wall Panels: The NPW-I wall panels must be installed vertically between vertical mullions or posts spaced a maximum of 48 inches (1210 mm) on center that provide panels with a minimum 2-inch wide (51 mm) bearing support to the panels for wind loads. All panel edges must be protected from the weather with aluminum extrusions or metal flashing.

5.0 CONDITIONS OF USE:

The Four Seasons Building Products, LLC, laminated foam roof panels and NPW-I wall panels described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 Panel fabrication, identification and installation must comply with this report and the manufacturer's published installation instructions. In the event of conflicts between this report and the manufacturer's published instructions, this report governs.
- 5.2 The panels are limited to use in patio covers regulated under Appendix I of the IBC and Appendix AH of the 2021 IRC (Appendix H of the 2018, 2015, 2012 and 2009 IRC).
- 5.3 Design loads must not exceed the allowable loads set forth in this evaluation report.
- 5.4 As permitted by Section 4.2.1 of this evaluation report, panel to support connections may use fasteners described in Section 3.2.1.4, provided an engineering design by a registered design professional is submitted to code official for approval, and the engineering design must consider all applicable limit states, such as pull-over strength as described in Section 3.2.1.4, and screw strength and screw pull-out strength, which are outside the scope of this evaluation report.
- 5.5 Panel connections to the supporting structure must be designed in accordance with the applicable code and this evaluation report, and must be submitted to the code official for approval. Panel connection details must be prepared by a registered design professional where required by the jurisdiction in which the structure is to be constructed.
- 5.6 The remaining portions of the structure must be designed and constructed in accordance with the applicable code.
- 5.7 Calculations and drawings demonstrating compliance with this evaluation report and the applicable code must be submitted to the code official for approval. The calculations and drawings must be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.8 The wall and roof panels are manufactured at Buena Park, California, with inspections by ICC-ES. Roof panels are also manufactured in Groveland, Florida, with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

Data in accordance with the [ICC-ES Acceptance Criteria for Sandwich Panels \(AC04\)](#), dated June 2019 (editorially revised December 2020).

Data in accordance with the [ICC-ES Acceptance Criteria for Foam Plastic Insulation \(AC12\)](#), dated June 2015 (editorially revised October 2020).

7.0 IDENTIFICATION

- 7.1 A label must be affixed to each panel, bearing the company name (Four Seasons Building Products, LLC), address (Buena Park, California or Groveland, Florida), product name/type (Insulated Foam Roof Panel or NPW-I Wall panel, as applicable), product component description for Insulated Foam Roof Panels (such as 1.0 pcf EPS – 0.024 inch facer), and the evaluation report number (ESR-2229).
- 7.2 The report holder's contact information is the following:

FOUR SEASONS BUILDING PRODUCTS, LLC
5005 VETERANS MEMORIAL HIGHWAY
HOLBROOK, NEW YORK 11741
(800) 457-9959
www.fourseasonsbuildingproducts.com

TABLE 1—ALLOWABLE SPANS FOR ROOF PANELS WITH 1.5 PCF EPS CORE⁽¹⁾⁽²⁾⁽³⁾⁽⁴⁾⁽⁵⁾⁽⁷⁾⁽⁹⁾

PANEL DESCRIPTION			Load Type	APPLIED PRESSURE FOR DESIGN										Min. Panel Slope (per ft of projection) ⁽⁶⁾	
Nominal Core Thickness (inches)	Nominal Facer Thickness (inches)	Optional Channel Beam ⁽⁸⁾		10 psf	15 psf	20 psf	25 psf	30 psf	35 psf	40 psf	45 psf	50 psf	55 psf		
3	0.024	No	Live	16'-8"		13'-1"								3/8" / foot	
			Wind (Upward)	17'-9"	15'-2"	13'-6"	12'-4"	11'-6"	10'-9"	10'-2"	9'-8"	8'-11"	8'-1"	n/a	
			Wind (Downward)	16'-8"	14'-6"	13'-1"	12'-0"	11'-2"	10'-6"	10'-0"	9'-6"	8'-7"	7'-10"	7'-10"	n/a
			Snow			12'-7"	11'-7"	10'-10"	10'-2"	9'-8"	9'-2"	8'-7"	7'-10"	7'-10"	1/2" / foot
3	0.024	Yes	Live	16'-8"		13'-1"								3/8" / foot	
			Wind (Upward)	17'-6"	14'-11"	13'-3"	12'-1"	10'-7"	9'-0"	7'-11"	7'-0"	6'-3"	5'-8"	n/a	
			Wind (Downward)	16'-8"	14'-6"	13'-1"	12'-0"	11'-2"	10'-5"	9'-10"	9'-2"	8'-3"	7'-6"	7'-6"	n/a
			Snow			12'-6"	11'-6"	10'-6"	9'-9"	9'-2"	8'-8"	8'-2"	7'-6"	7'-6"	1/2" / foot
3.5	0.024	No	Live	18'-5"		14'-6"								3/8" / foot	
			Wind (Upward)	19'-8"	16'-10"	15'-0"	13'-9"	12'-10"	12'-0"	11'-5"	10'-10"	10'-4"	9'-8"	9'-8"	n/a
			Wind (Downward)	18'-5"	16'-1"	14'-6"	13'-5"	12'-6"	11'-9"	11'-2"	10'-8"	10'-3"	9'-4"	9'-4"	n/a
			Snow			14'-0"	12'-11"	12'-1"	11'-5"	10'-9"	10'-2"	9'-8"	9'-2"	9'-2"	1/2" / foot
3.5	0.024	Yes	Live	18'-2"		14'-4"								3/8" / foot	
			Wind (Upward)	19'-6"	16'-8"	14'-11"	13'-4"	12'-2"	11'-2"	9'-9"	8'-8"	7'-9"	7'-1"	7'-1"	n/a
			Wind (Downward)	18'-2"	15'-11"	14'-4"	13'-2"	12'-4"	11'-7"	11'-0"	10'-6"	10'-0"	9'-4"	9'-4"	n/a
			Snow			13'-10"	12'-6"	11'-5"	10'-7"	9'-11"	9'-5"	8'-11"	8'-6"	8'-6"	1/2" / foot
4	0.024	No	Live	19'-10"		15'-8"								3/8" / foot	
			Wind (Upward)	21'-4"	18'-2"	16'-3"	14'-10"	13'-9"	12'-11"	12'-3"	11'-7"	11'-1"	10'-8"	10'-8"	n/a
			Wind (Downward)	19'-10"	17'-4"	15'-8"	14'-5"	13'-5"	12'-8"	12'-0"	11'-5"	10'-11"	10'-5"	10'-5"	n/a
			Snow			15'-1"	13'-8"	12'-7"	11'-8"	10'-11"	10'-4"	9'-9"	9'-4"	9'-4"	1/2" / foot
4	0.024	Yes	Live	19'-7"		15'-5"								3/8" / foot	
			Wind (Upward)	21'-2"	17'-6"	15'-1"	13'-5"	12'-3"	11'-3"	10'-6"	9'-11"	8'-11"	8'-1"	8'-1"	n/a
			Wind (Downward)	19'-7"	17'-1"	15'-5"	14'-2"	13'-0"	12'-1"	11'-4"	10'-8"	10'-2"	9'-8"	9'-8"	n/a
			Snow			14'-1"	12'-8"	11'-7"	10'-9"	10'-1"	9'-6"	9'-1"	8'-8"	8'-8"	1/2" / foot
6	0.024	No	Live	23'-0"		20'-4"								1/4" / foot	
			Wind (Upward)	23'-0"	23'-0"	21'-7"	19'-2"	17'-6"	16'-2"	15'-1"	14'-2"	13'-5"	12'-10"	12'-10"	n/a
			Wind (Downward)	23'-0"	23'-0"	20'-4"	18'-4"	16'-10"	15'-7"	14'-8"	13'-10"	13'-2"	12'-6"	12'-6"	n/a
			Snow			18'-3"	16'-5"	15'-0"	14'-0"	13'-1"	12'-4"	11'-9"	11'-3"	11'-3"	3/8" / foot
6	0.024	Yes	Live	23'-0"		18'-9"								1/4" / foot	
			Wind (Upward)	23'-0"	20'-3"	17'-5"	15'-6"	14'-1"	13'-0"	12'-2"	11'-5"	10'-10"	10'-4"	10'-4"	n/a
			Wind (Downward)	23'-0"	21'-4"	18'-9"	16'-10"	15'-6"	14'-4"	13'-6"	12'-9"	12'-1"	11'-6"	11'-6"	n/a
			Snow			16'-9"	15'-1"	13'-10"	12'-10"	12'-1"	11'-5"	10'-10"	10'-4"	10'-4"	3/8" / foot
3	0.032	No	Live	18'-3"		14'-4"								3/8" / foot	
			Wind (Upward)	19'-8"	16'-9"	14'-11"	13'-8"	12'-8"	11'-10"	11'-2"	10'-8"	10'-2"	9'-9"	9'-9"	n/a
			Wind (Downward)	18'-3"	15'-11"	14'-4"	13'-3"	12'-4"	11'-7"	11'-0"	10'-5"	10'-0"	9'-7"	9'-7"	n/a
			Snow			13'-9"	12'-8"	11'-10"	11'-2"	10'-7"	10'-1"	9'-8"	9'-3"	9'-3"	1/2" / foot
3	0.032	Yes	Live	18'-1"		14'-2"								3/8" / foot	
			Wind (Upward)	19'-6"	16'-7"	14'-9"	13'-6"	12'-6"	11'-8"	11'-0"	10'-5"	9'-6"	8'-7"	8'-7"	n/a
			Wind (Downward)	18'-1"	15'-9"	14'-2"	13'-0"	12'-1"	11'-4"	10'-9"	10'-2"	9'-9"	9'-4"	9'-4"	n/a
			Snow			13'-6"	12'-6"	11'-7"	10'-11"	10'-4"	9'-10"	9'-5"	9'-0"	9'-0"	1/2" / foot
3.5	0.032	No	Live	20'-6"		16'-2"								3/8" / foot	
			Wind (Upward)	22'-1"	18'-10"	16'-10"	15'-4"	14'-3"	13'-4"	12'-8"	12'-0"	11'-6"	11'-0"	11'-0"	n/a
			Wind (Downward)	20'-6"	17'-10"	16'-2"	14'-10"	13'-10"	13'-0"	12'-4"	11'-9"	11'-3"	10'-10"	10'-10"	n/a
			Snow			15'-6"	14'-3"	13'-4"	12'-7"	11'-11"	11'-4"	10'-11"	10'-5"	10'-5"	1/2" / foot
3.5	0.032	Yes	Live	20'-3"		15'-11"								3/8" / foot	
			Wind (Upward)	22'-0"	18'-8"	16'-8"	15'-2"	14'-1"	13'-2"	12'-5"	11'-9"	10'-10"	9'-10"	9'-10"	n/a
			Wind (Downward)	20'-3"	17'-8"	15'-11"	14'-7"	13'-7"	12'-9"	12'-1"	11'-6"	11'-0"	10'-6"	10'-6"	n/a
			Snow			15'-3"	14'-0"	13'-1"	12'-4"	11'-8"	11'-1"	10'-8"	10'-2"	10'-2"	1/2" / foot
4	0.032	No	Live	21'-10"		17'-3"								3/8" / foot	
			Wind (Upward)	23'-0"	20'-2"	18'-0"	16'-5"	15'-3"	14'-3"	13'-6"	12'-10"	12'-3"	11'-9"	11'-9"	n/a
			Wind (Downward)	21'-10"	19'-1"	17'-3"	15'-10"	14'-9"	13'-11"	13'-2"	12'-7"	12'-0"	11'-6"	11'-6"	n/a
			Snow			16'-7"	15'-3"	14'-3"	13'-5"	12'-9"	12'-2"	11'-8"	11'-2"	11'-2"	1/2" / foot
4	0.032	Yes	Live	21'-7"		16'-11"								3/8" / foot	
			Wind (Upward)	23'-0"	20'-0"	17'-10"	16'-1"	14'-7"	13'-6"	12'-7"	11'-10"	11'-3"	10'-9"	10'-9"	n/a
			Wind (Downward)	21'-7"	18'-10"	16'-11"	15'-7"	14'-6"	13'-8"	12'-11"	12'-3"	11'-9"	11'-3"	11'-3"	n/a
			Snow			16'-3"	15'-0"	13'-10"	12'-10"	12'-0"	11'-4"	10'-10"	10'-4"	10'-4"	1/2" / foot
6	0.032	No	Live	23'-0"		22'-8"								3/8" / foot	
			Wind (Upward)	23'-0"	23'-0"	23'-0"	21'-9"	20'-1"	18'-10"	17'-10"	16'-10"	15'-11"	15'-2"	15'-2"	n/a
			Wind (Downward)	23'-0"	23'-0"	22'-8"	20'-10"	19'-5"	18'-3"	17'-4"	16'-4"	15'-6"	14'-10"	14'-10"	n/a
			Snow			21'-6"	19'-4"	17'-9"	16'-6"	15'-6"	14'-7"	13'-11"	13'-3"	13'-3"	1/2" / foot
6	0.032	Yes	Live	23'-0"		22'-1"								1/4" / foot	
			Wind (Upward)	23'-0"	23'-0"	20'-8"	18'-5"	16'-9"	15'-5"	14'-5"	13'-7"	12'-10"	12'-3"	12'-3"	n/a
			Wind (Downward)	23'-0"	23'-0"	22'-1"	19'-11"	18'-3"	17'-0"	15'-11"	15'-0"	14'-4"	13'-8"	13'-8"	n/a
			Snow			19'-9"	17'-9"	16'-4"	15'-2"	14'-3"	13'-5"	12'-9"	12'-3"	12'-3"	3/8" / foot

For SI: 1 inch = 25.4 mm, 1 foot = 305 mm, 1 psf = 47.9 Pa.

Table 1 Notes:

- ⁽¹⁾Roof Panels are limited for use with a patio enclosure as defined in Appendix Chapter I of the *International Building Code*® (IBC) and Appendix Chapter AH of the *International Residential Code*® (IRC) (Appendix Chapter H of 2018, 2015, 2012 and 2009 of IRC).
- ⁽²⁾The Applied Pressure for Design (column headings) shown in the table is an "equivalent" uniform load. Consideration shall be given to load combinations presented in the Code and site specific conditions such as drifting and sliding snow. After determination of the applied pressure, the allowable panel span is determined for each load type using the greatest calculated pressure for all load combinations which include the specific load type. This process is repeated for each of the four (4) load types. The minimum allowable span calculated for each of the 4 load types shall be the "Allowable Span" used for the proposed application.
- ⁽³⁾Unless otherwise noted, the maximum eave projection of the roof system is 24 inches.
- ⁽⁴⁾Panel Spans are based on a maximum temperature differential between the two panel skins of 10 degrees in Fahrenheit.
- ⁽⁵⁾Panel to support connections must conform to Sections 4.1.1 and 4.2.1 of this evaluation report.
- ⁽⁶⁾Minimum panel slopes are based on panel deflection only. Increased slopes will be required where panel accessories, such as mullions or flashing, can increase ponding caused by irregularities in the water flow path.
- ⁽⁷⁾The spans are based on single span, simply supported installations.
- ⁽⁸⁾Consideration has been given to the addition of one (1) ceiling fan per 4'-wide panel with a maximum fan weight of 50 pounds. Therefore, the allowable loads provided above are in addition to the weight of the ceiling fan.
- ⁽⁹⁾The tabulated panel spans are also applicable when panels are subject to maintenance live load of 300 pounds, which must not be combined with the uniform live load, as prescribed in IBC Section 1607.4 and Table 1607.1.

TABLE 2—ALLOWABLE SPANS FOR ROOF PANELS WITH 1.0 PCF EPS CORE^{(1)(2)(3)(4) (5)(7)(9)}

PANEL DESCRIPTION			0.024" SKIN – 3" THICK, 1.0 PCF EPS CORE - 0.024" SKIN - WITHOUT FAN BEAM										Minimum Panel Slope (Per Foot of Projection) ⁽⁶⁾	
			Loading Type	Applied Pressure for Design (psf)										
Nominal Core Thickness (inches)	Nominal Facer Thickness (inches)	Optional Channel Beam ⁽⁸⁾		10	15	20	25	30	35	40	45	50	55	
3	0.024	No	Live	16'-5"		12'-5"								3/8" / foot
			Wind (Upward)	17'-5"	14'-7"	12'-10"	11'-6"	10'-6"	9'-9"	8'-9"	7'-9"	6'-11"	6'-4"	n/a
			Wind (Downward)	16'-5"	14'-0"	12'-5"	11'-2"	10'-3"	9'-6"	8'-5"	7'-6"	6'-9"	6'-2"	n/a
			Snow			11'-10"	10'-8"	9'-9"	9'-0"	8'-5"	7'-6"	6'-9"	6'-2"	1/2" / foot

For SI: 1 inch = 25.4 mm, 1 foot = 305 mm, 1 psf = 47.9 Pa.

Refer to [Table 1](#) for Notes.

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 40 00—Roofing and Siding Panels

REPORT HOLDER:

FOUR SEASONS BUILDING PRODUCTS, LLC

EVALUATION SUBJECT:

LAMINATED FOAM ROOF AND NPW-I WALL PANELS

1.0 REPORT PURPOSE AND SCOPE**Purpose:**

The purpose of this evaluation report supplement is to indicate that Laminated Foam Roof and NPW-I Wall Panels, described in ICC-ES evaluation report ESR-2229, have also been evaluated for compliance with the codes noted below.

Applicable code edition(s):

- 2022 and 2019 *California Building Code*® (CBC)

For evaluation of applicable chapters adopted by the California Office of Statewide Health Planning and Development (OSHPD) AKA: California Department of Health Care Access and Information (HCAI) and the Division of State Architect (DSA), see Sections 2.1.1 and 2.1.2 below.

- 2022 and 2019 *California Residential Code*® (CRC)

2.0 CONCLUSIONS**2.1 CBC:**

The Laminated Foam Roof and NPW-I Wall Panels, described in Sections 2.0 through 7.0 of the evaluation report ESR-2229, comply with 2022 and 2019 CBC Chapters 8, 15, 20, 23, 26 and Appendix I, provided the design and installation are in accordance with the 2021 and 2018 *International Building Code*® (IBC) provisions, respectively, noted in the evaluation report and the additional requirements of 2022 and 2019 CBC Chapters 8, 14, 15, 20, 23, 26 and Appendix I, as applicable.

The Laminated Foam Roof and NPW-I Wall Panels have not been evaluated under CBC Chapter 7A for use in the exterior design and construction of new buildings located in any Fire Hazard Severity Zone within State Responsibility Areas or any Wildland-Urban Interface Fire Area.

2.1.1 OSHPD: The applicable OSHPD Sections and Chapters of the CBC are beyond the scope of this supplement.

2.1.2 DSA: The applicable DSA Sections and Chapters of the CBC are beyond the scope of this supplement.

2.2 CRC:

The Laminated Foam Roof and NPW-I Wall Panels, described in Sections 2.0 through 7.0 of the evaluation report ESR-2229, complies with 2022 and 2019 CRC Chapters 3, 7, 9 and Appendix AH and H, provided the design and installation are in accordance with the 2021 and 2018 *International Residential Code*® (IRC) provisions, respectively, noted in the evaluation report and the additional requirements of 2022 and 2019 CRC Chapters 3, 9 and Appendix AH and H, as applicable.

The Laminated Foam Roof and NPW-I Wall Panels have not been evaluated under CRC Section R337 for use in the exterior design and construction of new buildings located in any Fire Hazard Severity Zone within State Responsibility Areas or any Wildland-Urban Interface Fire Area.

The products recognized in this supplement have not been evaluated for compliance with the *International Wildland-Urban Interface Code*®.

This supplement expires concurrently with the evaluation report, reissued May 2024.

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 40 00—Roofing and Siding Panels

REPORT HOLDER:

FOUR SEASONS BUILDING PRODUCTS, LLC

EVALUATION SUBJECT:

LAMINATED FOAM ROOF AND NPW-I WALL PANELS

1.0 REPORT PURPOSE AND SCOPE**Purpose:**

The purpose of this evaluation report supplement is to indicate that the Four Seasons Building Products, LLC, laminated foam roof panels and NPW-I wall panels, described in ICC-ES evaluation report ESR-2229, have also been evaluated for compliance with the code noted below.

Applicable code editions:

- 2023 and 2020 *Florida Building Code—Building*
- 2023 and 2020 *Florida Building Code—Residential*

2.0 CONCLUSIONS

The Four Seasons Building Products, LLC, laminated foam roof panels and NPW-I wall panels, described in Sections 2.0 through 7.0 of ICC-ES evaluation report ESR-2229, comply with the *Florida Building Code—Building* and the *Florida Building Code—Residential*. The design requirements shall be determined in accordance with the *Florida Building Code—Building*, as applicable. The installation requirements noted in ICC-ES evaluation report ESR-4659 for the 2021 and 2018 *International Building Code*® meet the requirements of the *Florida Building Code—Building* and the *Florida Building Code—Residential*, as applicable.

Use of the Four Seasons Building Products, LLC, laminated foam roof panels and NPW-I wall panels have also been found to be in compliance with the High-Velocity Hurricane Zone provisions of the *Florida Building Code—Building* and *Florida Building Code—Residential*.

For products falling under Florida Rule 61G20-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official when the report holder does not possess an approval by the Commission).

This supplement expires concurrently with the evaluation report, reissued May 2024.