

ICC-ES Evaluation Report


ESR-2799

Reissued July 2024

Subject to renewal July 2026

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

Copyright © 2024 ICC Evaluation Service, LLC. All rights reserved.

<p>DIVISION: MBTECHNOLOGY</p> <p>Section: 07 30 05— Roofing Felt and Underlayment</p>	<p>REPORT HOLDER: MBTECHNOLOGY</p>	<p>EVALUATION SUBJECT:</p> <p>LAYFAST SBS ROOF UNDERLAYMENTS: TU35, TU43, AND TU70</p>	
--	--	--	---

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2012, 2009 and 2006 [International Building Code® \(IBC\)](#)
- 2012, 2009 and 2006 [International Residential Code® \(IRC\)](#)
- 1997 *Uniform Building Code™* (UBC)

Properties evaluated:

- Durability
- Physical properties

2.0 USES

Layfast SBS roof underlayments are for use as alternatives to the ASTM D226, Type I and Type II, underlayment specified in Chapter 15 of the IBC and Chapter 9 of the IRC; and to the Type 15 and Type 30 underlayments specified in Chapter 15 of the UBC. The Layfast SBS roof underlayments are used with asphalt shingles, tile, wood shingles or shakes, and metal roofing.

3.0 DESCRIPTION

The sheet materials are fiberglass-reinforced SBS modified membranes, available in rolls 39³/₄ inches wide (1000 mm) and having a nominal weight of 36.4 pounds per 100 square feet (TU35), 41.0 pounds per 100 square feet (TU43), and 63.2 pounds per 100 square feet (TU70). The membranes are coated on both sides with a fine mineral parting agent.

4.0 INSTALLATION

The underlayments must be installed over solid sheathing. Application must comply with Chapter 15 of the IBC and UBC and Chapter 9 of the IRC, as applicable. The membrane is applied at right angles to the slope of the roof, beginning at the low point of the roof. Sidelaps are a minimum of 2 inches (51 mm) and are nailed at 12 inches (305 mm) on center. End laps are a minimum of 6 inches (152 mm) and are nailed at 6 inches (152 mm) on center. Nails must be corrosion-resistant capped nails complying with the applicable code. Installation of the roof covering can proceed immediately following application of the membrane. The membrane should be covered by an approved roof covering as soon as possible.

5.0 CONDITIONS OF USE:

The Layfast SBS roof underlayments described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 The underlayment must be manufactured, identified, and installed in accordance with this report and the manufacturer's instructions. In the event of a conflict between this report and the manufacturer's instructions, this report governs.
- 5.2 Installation of underlayment is limited to roof slopes of 2:12 (16.67%) and greater and installations where the roof covering does not involve hot asphalt or coal-tar pitch.
- 5.3 Installation is limited to roofs with ventilated attic spaces in accordance with the requirements of the applicable code.
- 5.4 The underlayment is limited to use with roof coverings that are mechanically fastened through the underlayment to the sheathing or rafters.
- 5.5 Installation is limited to use with nonclassified roof coverings or as a component of a classified roofing assembly when specifically recognized as such in a listing approved by the code official.
- 5.6 The underlayment is manufactured in Fresno, California, under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

Data and reports of tests in accordance with the [ICC-ES Acceptance Criteria for SBS Modified Asphalt-coated Glass-fiber-mat Roof Underlayment \(AC165\)](#), dated October 2012.

7.0 IDENTIFICATION

- 7.1 Each roll is identified with the MBTechnology name and address, the evaluation report number (ESR-2799).
- 7.2 The report holder's contact information is the following:

MBTECHNOLOGY
188 SOUTH TEILMAN AVENUE
FRESNO, CALIFORNIA 93706
(559) 233-2181
www.mbtechnology.com