

ICC-ES Evaluation Report


ESR-3155

Reissued July 2024

Subject to renewal June 2025

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

Copyright © 2024 ICC Evaluation Service, LLC. All rights reserved.

<p>DIVISION: 07 00 00— THERMAL AND MOISTURE PROTECTION</p> <p>Section: 07 21 00— Thermal Insulation</p>	<p>REPORT HOLDER: EPSILYTE CANADA, ULC</p>	<p>EVALUATION SUBJECT: EPSILYTE® EXPANDABLE POLYSTYRENE (EPS) BEADS</p>	
---	--	---	---

1.0 EVALUATION SCOPE

Compliance with the following codes:

- 2012 and 2009 [International Building Code® \(IBC\)](#)
- 2012 and 2009 [International Residential Code® \(IRC\)](#)
- 2013 *Abu Dhabi International Building Code (ADIBC)*[†]

[†]The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

Properties evaluated:

- Surface-burning characteristics
- Physical properties
- Attic and crawl space evaluation

2.0 USES

The Epsilyte® expandable polystyrene beads are used by independent manufacturers to produce expanded polystyrene (EPS) insulation products.

3.0 DESCRIPTION

The expandable polystyrene beads are designated as resin Grades MA-500, MB-500, MC-500, MB-590 and MC-590. The EPS insulation products manufactured from the beads are produced through the introduction of steam into a heating chamber containing the beads. This process expands the beads, which are then molded into insulation products. At densities and thicknesses no greater than those specified in [Table 1](#), EPS insulation products produced from the beads have a flame-spread index of 25 or less and a smoke-developed index of 450 or less when tested in accordance with ASTM E84 or UL 723. The end use of the EPS beads, including the manufacture of the EPS products, is outside the scope of this report and must be addressed in a separate evaluation report.

Bead Types MA-500, MB-500, MC-500, MB-590 and MC-590 can be used to produce EPS products that comply with Types I, VIII, II, and IX [0.9, 1.15, 1.35 and 1.8 pcf and (15, 18, 22 and 29 kg/m³) minimum densities, respectively] of ASTM C578. The expanded polystyrene beads have been qualified in accordance with Section 4.5.15.1.1 of the ICC-ES Acceptance Criteria for Foam Plastic Insulation (AC12). The beads can be used to produce EPS products that comply with ASTM C578, for the types specified in [Table 1](#), provided the final product is recognized in a current ICC-ES evaluation report and has been qualified in accordance with Section 4.5.15.1.2 of AC12.

4.0 INSTALLATION

4.1 General:

Installation must be as noted in the corresponding current ICC-ES evaluation report on the EPS insulation product, or as otherwise permitted by the code official under Section 2603 of the IBC or Section R316 of the IRC, as applicable.

4.2 Attics and Crawl Spaces:

EPS insulation products produced from the EPS beads of the resin type, density, and thickness shown in [Table 2](#) of this report can be used on walls in attics and crawl spaces without a code-prescribed ignition barrier applied to the attic or crawl space side of the foam plastic, provided all of the following conditions are met:

- a. Entry to the attic or crawl space is only to service utilities, and no storage is permitted.
- b. There are no interconnected attic or crawl space areas.
- c. Air in the attic or crawl space is not circulated to other parts of the building.
- d. Attic ventilation is provided in accordance with IBC Section 1203.2 or IRC Section R806, as applicable.
- e. Under-floor (crawl space) ventilation is provided in accordance with IBC Section 1203.3 or IRC Section R408.1, as applicable.
- f. Combustion air is provided in accordance with IMC (*International Mechanical Code*[®]) Section 701.
- g. Thickness and density are limited to values listed in [Table 2](#).

5.0 CONDITIONS OF USE:

The Epsilyte[®] expandable polystyrene beads described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 The density and thickness of the EPS insulation boards produced from the expanded beads must be as noted in [Tables 1](#) and [2](#) of this report.
- 5.2 Products manufactured from the EPS beads must be recognized in a current ICC-ES evaluation report.
- 5.3 Except as noted in Section 4.2, the EPS insulation products produced from the EPS beads must be separated from the building interior by a thermal barrier complying with IBC Section 2603.4 and IRC Section R316.4, as applicable.
- 5.4 The beads are manufactured in Baie d'Urfe, Quebec, Canada, under a quality control program with inspections by ICC-ES.

6.0 EVIDENCE SUBMITTED

Data in accordance with the [ICC-ES Acceptance Criteria for Foam Plastic Insulation \(AC12\)](#), dated June 2012, including reports of tests in accordance with Appendix B of AC12.

7.0 IDENTIFICATION

- 7.1 The ICC-ES mark of conformity, electronic labeling, or the evaluation report number (ICC-ES ESR-3155) along with the name, registered trademark, or registered logo of the report holder must be included in the product label.
- 7.2 In addition, each container of beads is labeled with the report holder's name (Epsilyte Canada, ULC) and address, the production plant country (made in the United States or made in Canada), and the bead type.
- 7.3 The report holder's contact information is the following:

EPSILYTE CANADA, ULC
19250 CLARK GRAHAM
BAIE D'URFE, QUEBEC H9X 3R8
CANADA
(514) 457-3226
www.epsilyte.com

TABLE 1—EPS PRODUCT DENSITY AND THICKNESS WHEN MADE WITH EPSILYTE® BEADS

EPS TYPE ¹	NOMINAL DENSITY (pcf)	MAXIMUM THICKNESS (inches) FOR BEAD TYPES MA-500, MB-500, MC-500, MB-590, MC-590
I	1.0	6
VIII	1.25	6
II	1.50	6
IX	2.0	6

For **SI**: 1 pcf = 16.02 kg/m³, 1 inch = 25.4 mm.

¹Type as designated in ASTM C578.

TABLE 2—MAXIMUM DENSITY AND MAXIMUM THICKNESS FOR EPS PRODUCTS USED IN ATTICS OR CRAWL SPACES

MAXIMUM DENSITY (pcf)	MAXIMUM THICKNESS (inches) FOR BEAD TYPES MA-500, MB-500, MC-500, MB-590, MC-590
1.0	4
1.5	2.6
2.0	2

For **SI**: 1 pcf = 16.02 kg/m³, 1 inch = 25.4 mm.