



CSI: DIVISION: 22 00 00—PLUMBING
Section: 22 40 00—Plumbing Fixtures
Section: 22 09 00—Instrumentation and Control for Plumbing

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Product: Combination Commercial Electric Lavatory Faucet and Hand Dryer

Listee: Dyson Technology Limited
Malmesbury, Wilshire SN16 0RP
England
www.dyson.com

Compliance with the following codes:

2024, 2021, 2018, 2015, 2012 and 2009 *International Plumbing Code*® (IPC)
2021, 2018, 2015, 2012 and 2009 *International Residential Code*® (IRC)
2024, 2021, 2018, 2015, 2012 and 2009 *Uniform Plumbing Code*® (UPC)*
2020, 2015, 2010 and 2005 *National Plumbing Code of Canada*® (NPC)**

* Copyrighted publication of the International Association of the Plumbing and Mechanical Officials

** National Plumbing Code of Canada is a copyrighted publication of the National Research Council of Canada

Compliance with the following standards:

ASME A112.18.1/CSA B125.1-2018 Plumbing Supply Fittings
NSF/ANSI/CAN 61-2023, Drinking Water System Components – Health Effect
UL 507 (ed. 9), Electronic Fans
CSA C22.2 No. 60335-1:16(R2021), Household and Similar Electrical Appliances – Part 1: General Requirements

Identification:

The Dyson Airblade Tap or Dyson Airblade Wash + Dry shall be marked with the manufacturer's recognized name, trademark, or other mark; or in the case of private labeling, the name, trademark, or other mark of the customer for whom the fitting was manufactured, model number and the ICC-ES PMG listing mark.

Installation:

The Dyson Airblade Tap or Dyson Airblade Wash + Dry must be installed in by a qualified electrician and plumber in accordance with the manufacturer's instructions and the applicable code. Before installing or using the unit, all instructions and cautionary markings in the owner's manual and the

installation guide must be read and adhered. Dyson recommends a 15 amp circuit breaker with a dedicated line and neutral.

The hand dryer must be installed in dry, internal locations only. A thermostatic mixer is recommended (not supplied) by manufacturer to be installed so that hot water delivered from this product is limited to a maximum temperature of 120°F (49°C).

The Dyson Airblade Tap and Dyson Airblade Wash + Dry are compatible with most sink types. Sinks with highly polished surfaces should be avoided (e.g. shiny chrome). The sink should not be fitted with a drain plug. Do not use sealant when fixing the unit to the wall.

Model:

The lead test statistic Q for all models listed below have been found not to exceed 1 µg when normalized for the 1 L (0.26 gal) first draw sample (Q ≤ 1) in accordance with Annex 7 of NSF/ANSI/CAN 61.

AB09 Dyson Airblade Tap – Counter Mount, Short
AB10 Dyson Airblade Tap – Counter Mount, Long
AB11 Dyson Airblade Tap – Wall Mount
WD04 Dyson Airblade Wash + Dry – Counter Mount, Short
WD05 Dyson Airblade Wash + Dry – Counter Mount, Long
WD06 Dyson Airblade Wash + Dry – Wall Mount

* Additional information on electronic fan components can be found under the ETL Listing Directory

Conditions of Listing:

1. The Dyson Airblade Taps or Dyson Airblade Wash + Dry recognized in this listing must be installed by a qualified electrician and plumber in accordance with the manufacturer's published installation instructions and the applicable codes.
2. Installation instruction must include language in English and French.
3. Before installing or using the unit, all instructions and cautionary markings in the owner's manual and the installation guide must be read and adhered.
4. A thermostatic mixer is recommended (not supplied) by manufacturer to be installed so that hot water delivered from this product is limited to a maximum temperature of 120°F (49°C).
5. The Dyson Airblade Taps or Dyson Airblade Wash + Dry recognized in this listing are manufactured under a quality control program with annual surveillance inspections by ICC-ES.