



ICC-ES Report

PMG-1278

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

Reissued 08/2024
This report is subject to renewal 08/2025

EVALUATION SUBJECT:

SURFACE BURNING CHARACTERISTICS FOR SPEARS EVERTUFF® AND LABWASTE® CPVC PIPE AND FITTINGS

DIVISION:

23 00 00—MECHANICAL

SECTION:

23 00 00—HVAC

Report Holder:

SPEARS MANUFACTURING COMPANY

Look for the ICC-ES
mark of Conformity!



ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report. Copyright © 2024 ICC Evaluation Service, LLC. All rights reserved.





CSI: DIVISION: 23 00 00—MECHANICAL
Section: 23 00 00—HVAC

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Product: Surface Burning Characteristics for Spears EverTUFF® and LabWaste® CPVC Pipe and Fittings

Listee: Spears Manufacturing Company
15853 Olden Street
Sylmar, California 91342

Compliance with the following codes:

2024, 2021, 2018, 2015, 2012, 2009 and 2006 *International Mechanical Code®* (IMC)
2018, 2015, 2012, 2009 and 2006 *Uniform Mechanical Code®* (UMC)*

**Copyrighted publication of the International Association of Plumbing and Mechanical Officials*

Compliance with the following standards:

ASTM E 84-23d, Test Method for Surface Burning Characteristics of Building Materials
UL 723 (Ed. 11), Test for Surface Burning Characteristics of Building Materials

Identification:

Pipe must bear the manufacturer's name or trademark, test standard, rating and the ICC-ES PMG listing mark.

Fittings must bear manufacturer's name or trademark, nominal size and a third party certification mark. Packaging must be marked with test standard, rating and ICC-ES PMG listing mark.

Installation:

The pipe and fittings are to be installed in accordance with the manufacturer's instructions and the applicable code.

Installation of pipe and fittings within ducts and plenums shall be in accordance with Section 602 of the IMC or 602.0 of the UMC

Models:

The following CPVC pipe and fittings models have been tested dry as a single row of pipe measuring 288.0 inches in length as a modified* version of UL 723 / ASTM E84, Test Methods for Surface Burning Characteristics. The following ratings were obtained and have been found to meet the 25/50 flame spread/smoke developed requirements.

- 1/2" – 2" dry EverTUFF® SDR 11 CPVC pipe and fittings have a flame spread index of 0 and a smoke developed index of no more than 25.
 - 1/2" – 6" dry Spears EverTUFF® Industrial CPVC pipe and fittings have a flame spread index of 0 and a smoke developed index of no more than 25.
 - 1-1/2" – 6" dry Spears LabWaste® CPVC pipe and fittings for corrosive waste have a flame spread index of 0 and a smoke developed index of no more than 25.
- * The specimens tested are not conducive to full coverage of the 20 in. x 24 ft. test sample as specified by UL 723/ASTM E84. Therefore, only a certain portion of the total area exposed to the flame is covered by the test samples. The tested specimens are representative models of finish product.

Conditions of listing:

1. The pipe and fitting models recognized by this listing have been evaluated for surface burning characteristics only. Evaluation of the CPVC pipe and fittings to the applicable performance standard in accordance with Chapter 6 of the IPC or UPC is outside the scope of this report.
2. The plumbing systems must be installed in accordance with the applicable codes.
3. The pipe and fittings are manufactured under a quality control program with annual surveillance inspections by ICC-ES.