

# **ICC-ES PMG Product Certificate**





**PMG-1359** 

Effective Date: October 2024 This listing is subject to re-examination in one year.

www.icc-es-pmg.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 22 00 00—PLUMBING

Section: 22 40 00—Facility Water Distribution

Section: 22 09 00—Instrumentation and Control for Plumbing

# Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Product: Backflow Preventers with an Intermediate Atmospheric Vent

Listee: CALEFFI North America, Inc.

3883 W. Milwaukee Road Milwaukee, WI 53208

www.caleffi.us

#### Compliance with the following codes:

2024, 2021, 2018, 2015, 2012 and 2009 International Plumbing Code® (IPC) 2024, 2021, 2018, 2015, 2012 and 2009 International Residential Code® (IRC) 2024, 2021, 2018, 2015, 2012 and 2009 Uniform Plumbing Code® (UPC)\*

\* Copyrighted publication of the International Association of Plumbing and Mechanical Officials

### Compliance with the following standards:

ASSE 1012-2021, Performance Requirements for Backflow Preventers with an Intermediate Atmospheric Vent

#### Identification:

Each device shall have the following information marked on it and all markings shall be visible after installation:

- a) The manufacturer's recognized name, trademark, or other mark; or
- b) Model number
- c) Maximum rated working pressure
- d) Maximum water temperature for which device is designed
- e) Serial number or other marking consistent with the manufacturer's standard practice
- f) Nominal valve size
- g) Direction of water flow through device
- h) The ICC-ES PMG listing mark

Markings shall be clear, permanent, and visible after installation.



### Installation:

Products recognized in this listing shall be installed in accordance with the manufacturer's instructions and the applicable codes.

## Models:

Model No.	Description
573403A	1/2" NPT female inlet/outlet
573406A	1/2" press inlet/outlet
573409A	1/2" sweat inlet/outlet
573493A	1/2" sweat inlet x 1/2" FNPT outlet
573503A	3/4" NPT female inlet/outlet
573509A	3/4" sweat inlet/outlet

## Conditions of listing:

- 1. The CALEFFI's products recognized in this listing must be installed in accordance with the manufacturer's published installation instructions and the applicable codes.
- 2. The CALEFFI's products recognized in this listing are manufactured under a quality control program with annual surveillance inspections by ICC-ES.