

# ICC-ES PMG Product Certificate 🖳 ANAB



# **PMG-1437**

Effective Date: August 2024 This listing is subject to re-examination in one year.

www.icc-es-pmg.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 22 00 00-PLUMBING Section: 22 11 16—Domestic Water Piping DIVISION: 23 00 00-HEATING, VENTILATING AND AIR CONDITIONING (HVAC) Section: 23 21 13—Hydronic Heating

Product certification system:

S

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

- Products: Aquatechnik Safety®-Plus PEX-AL-PEX Pipe and Fitting System
- Listee: Aquatechnik Group s.p.a Via P.F. Calvi, 40 Magnago (MI) 20020 Italy www.aquatechnik.it www.aquatechnikNA.com

Compliance with the following codes:

2024, 2021, 2018, 2015, 2012, 2009, 2006, and 2003 International Plumbing Code<sup>®</sup> (IPC) 2024, 2021, 2018, 2015, 2012, 2009, 2006, and 2003 International Residential Code® (IRC) 2024, 2021, 2018, 2015, 2012, 2009, 2006, and 2003 International Mechanical Code® (IMC) 2024, 2021, 2018, 2015, 2012, 2009, 2006, and 2003 Uniform Plumbing Code® (UPC)\* 2024, 2021, 2018, 2015, 2012, 2009, 2006, and 2003 Uniform Mechanical Code® (UMC)\* 2022, 2019, 2016, 2013 and 2010 California Plumbing Code (CPC) 2022, 2019, 2016, 2013 and 2010 California Mechanical Code (CMC) 2023, 2020 and 2017 City of Los Angeles Plumbing Code 2023, 2020 and 2017 City of Los Angeles Mechanical Code 2023 Florida Plumbing Code 2023 Florida Mechanical Code 2023, 2021 and 2017 Code of Massachusetts Regulation 248 CMR 10.00: Uniform State Plumbing Code 2023, 2021 and 2017 Massachusetts State Building Code 780 CMR Ninth Edition: Chapter 28 202 Uniform Illustrated Plumbing Code - India™ (UIPC-I)\* 2020, 2015 and 2010 National Plumbing Code of Canada® (NPC)\*\*

\*Copyrighted publication of the International Association of Plumbing and Mechanical Officials \*\* Copyrighted publication of the National Research Council Canada

Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this listing, or as to any product covered by the listing.



Compliance with the following standards:

ASTM F1281-2024, Standard Specification for Cross-linked Polyethylene/Aluminum/Cross-linked Polyethylene (PEX-AL-PEX) Pressure Pipe NSF/ANSI 14-2023, Plastic Piping Systems Components and Related Materials NSF/ANSI/CAN 61-2023, Drinking Water System Components – Health Effects CSA B137.10-2023 Crosslinked Polyethylene/Aluminum/Crosslinked Polyethylene (PEX-AL-PEX) Composite Pressure Pipe Systems

# Identification:

**Pipe:** The Aquatechnik PEX-AL-PEX pipe shall be marked every 5 feet (1.5 m) with the following: company name or trademark, material (PEX-AL-PEX), nominal size (for example, 1216), temperature and pressure ratings, ASTM F1281 designation, production code, pipe intended for the transport of potable water shall also include marking such as "PW" or "potable water", the ICC-ES PMG listing mark.

**Fittings**: Fittings shall be marked with manufacturer's name or trademark, and the ICC-ES PMG listing mark.

#### Installation:

Aquatechnik Safety<sup>®</sup>-Plus PEX-AL-PEX piping and fittings must be installed in accordance with the manufacturer's published installation instructions, the applicable codes and this listing. Where differences exist, the instructions in this listing must govern.

**Water Distribution:** Horizontally laid pipe must be secured in such a manner that temperatureinduced expansion and contraction are accommodated. In areas using the Uniform Plumbing Code (UPC), piping must not be installed within the first 18 inches (457 mm) of piping connected to a water heater. The system may be installed in concrete in accordance with the manufacturer's instructions. The piping must be secured to the concrete reinforcement (i.e. "rebar") to hold it in place while pouring concrete. When embedment is in concrete, installation, including minimum concrete cover, must comply with IBC Section 1907, or IRC Section R506.1, as applicable.

**Water Service:** Buried piping must be installed in such a manner that external loads do not decrease the vertical dimension of the cross section by more than 5 percent. Piping must be installed to provide an allowance for contraction of the line due to temperature change prior to backfilling. In areas with poor soil conditions (plastic clays), the trench bottom must be prepared using granular material to provide a stable base. Potable water service piping must not be located in, under or above cesspools, septic tanks, septic tank drainage fields or pits.

Water Distribution and Water Service Piping: Installed piping must be pressure-tested and inspected as required by IPC Section 606.6, IRC Section P2503.6 or UPC Section 103.5.

**Hydronic Piping Systems:** The installation must comply with Chapter 12 of the applicable mechanical code(s) and the manufacturer's published installation instructions. Details of the design and installation of the hydronic piping system must be submitted to the code official for approval. All circuits must be formed from continuous lengths of piping, from manifold supply to return. No splices are allowed. The system may be installed in either concrete or wood floors. When the system is embedded in concrete floors, a moisture barrier must be laid over a concrete base slab a minimum of 3<sup>1</sup>/<sub>2</sub> inches (38 mm) thick. Under-floor insulation and reinforcing mesh must then be placed on the slab. The piping must be uncoiled and attached to the mesh using soft steel wire. A concrete topping is then laid over the piping. When embedment is in concrete, installation, including minimum concrete cover, must comply with IBC Section 1906.3, or IRC Section R506.1, as applicable. When the piping is installed over polystyrene boards, the boards must comply with IBC Section 2603, or IRC Section R314, as applicable.

Antifreeze protection may be achieved by the addition of chemicals detailed in Item 1 of the Conditions of Listing, below. The quantity of these allowed chemicals required to achieve a specific freeze protection level is beyond the scope of this listing. Addition of antifreeze to the radiant heating loop must be in accordance with the manufacturer's installation instructions and the material safety data sheet (MSDS).

Mounting brackets and installation hardware are provided by the manufacturer. Horizontally laid pipe must be secured in such a way that temperature-induced expansion and contraction are accommodated.

**Hydronic Piping:** The piping must be pressure-tested for leaks before installation of covering, as noted in Section 1208 of the IMC, Section 1207 of the UMC, or Section M2103.3 of the IRC, as applicable. The leak test must be witnessed by the code official or the code official's designated representative.

# Models:

The pipe and fitting products have a maximum working temperature of 203°F (95°F) and a maximum working pressure of 145 psi (1 MPa). Fittings and pipe must be joined by a method of expansion with a double o-ring and proprietary non back off threads. Flanged, threaded, copper solder, and grooved adapter fittings are available for joining to other materials. Both pipe and fittings were tested as a system and fully meet the requirements of CSA B137.10 and ASTM F1281-2017 including Annex A2.

**Pipe:** Aquatechnik Safety<sup>®</sup>-Plus PEX-AL-PEX pipe is manufactured from cross-linked polyethylene (PEX) and aluminum materials satisfying ASTM F1281. The pipe is available in nominal pipe sizes from 1/2 inches (1216 mm) to 2-1/2 inches (6075 mm) (6075 mm).

Aquatechnik Safety<sup>®</sup>-Plus pipe are white in color with longitudinal red or blue stripe for potable water distribution or gray stripe for hydronic heating applications. The blue strip pipe is for cold water applications only. Pipe is also available in violet color for irrigation applications.

COD	Dimensions	Bar Length
74154U	½" x 0.08"	13 ft / 19 ft.
74156U	5∕%" x 0.08"	13 ft / 19 ft.
74158U	7∕₃" x 0.12"	13 ft / 19 ft.
74160U	1" x 0.12"	13 ft / 19 ft.
74162U	1 ¼" x 0.14"	13 ft / 19 ft.
74164U	1 ½ x 0.16"	13 ft / 19 ft.
74166U	2" x 0.18"	13 ft / 19 ft.
74168U	2½" x 0.20"	13 ft / 19 ft.
74170U	3" x 0.28"	13 ft / 19 ft.

COD	Dimensions	Roll Length
74004U1	½" x 0.08"	100 ft.
74004U10	½" x 0.08"	1000 ft.
74008U3	5∕8" x 0.08"	300 ft.
74008U5	5∕8" x 0.08"	500 ft.
74010U3	7∕8" x 0.12"	300 ft.
74012U1	1" x 0.12"	100 ft.

**Fitting**: Aquatechnik Safety<sup>®</sup>-Plus PPS Fittings of the following sizes can only be used on Aquatechnik PEX-AL-PEX pipe; fittings cannot be used with pipe from other manufacturer.

COD	Description	Dimension
20002U		M½" - sm½"
20006U	THREADED JOINT MALE, safety-plus, with PPS NPT thread	M½" - sm⁵⁄₅"
20010U		M³⁄₄" - sm⁵⁄₅"

20012U		M¾" - sm⅔"
20013U		M1"-sm <sup>7</sup> ∕₀"
20016U		M1" - sm1"
20018U		M 1¼" - sm 1¼"
20028U		M 1½" - sm 1½"
20033U		M 2" - sm 2"
20039U		M 2½" - sm 2½"
20062U		F½" - sm½"
20066U		F½" - sm⁵⁄₃"
20070U		F¾" - sm⁵⁄₅"
20072U		F¾" - sm⅔"
20073U	THREADED JOINT FEMALE, safety-plus, with PPS	F1" - sm‰"
20076U	NPT thread	F1" - sm1"
20076U		F 1" - sm 1"
20078U		F 1¼" - sm 1¼"
20088U		F 1½" - sm 1½"
20093U		F 2" - sm 2"
20122U		sf⁵⁄8" - sm½"
20126U		sf1⁄8" - sm1⁄2"
20130U		sf1⁄8" - sm5⁄8"
20132U		sf1" - sm½"
20136U		sf1" - sm%"
20138U	REDUCER, safety-plus	sf1" - sm%"
20142U		sf 1¼" - sm ½"
20144U		sf 1¼" - sm ⁵⁄s"
20146U		sf 1¼" - sm %"
20148U		sf 1¼" - sm 1"

20156U		sf 1½" - sm 1"
20158U		sf 1½" - sm 1¼"
20166U		sf 2" - sm 1"
20168U		sf 2" - sm 1¼"
20170U		sf 2" - sm 1½"
20178U		sf 2½" - sm 1"
20180U		sf 2½" - sm 1¼"
20182U		sf 2½" - sm 1½"
20184U		sf 2½" - sm 2"
20212U	THREADED ELBOW FEMALE, safety-plus, with PPS	F½" - sm½"
20216U	NPT thread, with bracket	F½" - sm%"
20222U		F½" - sm½"
20226U	THREADED ELBOW FEMALE, safety-plus, with PPS NPT thread	F½" - sm%"
20230U		F¾" - sm%"
20232U		F¾" - sm⅛"
20238U		F1" - sm1"
20282U		M½" - sm½"
20286U		M½" - sm⁵⁄₃"
20288U	THREADED ELBOW MALE, safety-plus, with PPS NPT thread	M¾" - sm%"
20290U		M³⁄4" - sm7⁄8"
20296U		M1" - sm1"
20332U		F½" - sf½"
20336U	THREADED ELBOW FEMALE/FEMALE, safety-plus,	F½" - sf⁵⁄₃"
20337U	with PPS NPT thread and turning cap	F¾" - sf7/8"
20338U		F1" - sf1"
20342U	THREADED ELBOW MALE/FEMALE, safety-plus,	M½" - sf½"
20344U	with PPS NPT thread and turning cap	M½" - sf⁵⁄8"

20346U		M³⁄4" - sf7⁄8"
20348U		M1" - sf1"
20352U		sf½" - sm½"
20356U		sf%" - sm%"
20358U	ELBOW 90°MALE/FEMALE, safety- plus, with turning cap	sf%" - sm%"
20360U		sf1" - sm1"
20362U		sf1¼" - sm1½"
20382U		sm½" - sm½"
20386U		sm⁵⁄₅" - sm⁵⁄₅"
20388U		sm¼" - sm⅓"
20390U		sm1" - sm1"
20392U	ELBOW 90°, safety-plus	sm 1¼" - sm 1¼"
20394U		sm 1½" - sm 1½"
20396U		sm 2" - sm 2"
20398U		sm 2½" - sm 2½"
20402U		sf½" - sf½"
20406U	ELBOW 90°FEMALE/FEMALE, safety-plus, with turning cap	sf⁵⁄8" - sf⁵⁄8"
20408U		sf7⁄8" - sf7⁄8"
20410U		sf1" - sf1"
20416U	ELBOW 45°, safety-plus	sm⁵‰" - sm⁵⁄₀"
20418U		sm⅔" - sm⅔"
20420U		sm1" - sm1"
20422U		sm 1¼" - sm 1¼"
20424U		sm 1½" - sm 1½"
20426U		sm 2" - sm 2"

20428U		sm 2½" - sm 2½"
20432U	ELBOW 45° M/F, safety-plus	sm%" - sm%"
20433U		sm <sup>7</sup> ‰" - sm <sup>7</sup> ‰"
204234U		sm1" - sm1"
20435U		sm 1¼" - sm 1¼"
20436U		sm 1½" - sm 1½"
20442U		sm½" - sm½"
20446U		sm%" - sm%"
20448U		sm‰" - sm%"
20450U		sm1" - sm1"
20452U	PIPE COUPLING, satety-plus	sm 1¼" - sm 1¼"
20454U		sm 1½" - sm 1½"
20456U		sm 2" - sm 2"
20458U		sm 2½" - sm 2½"
20472U	REDUCED PIPE COUPLING, safety-plus	sm⁵⁄₃" - sm¹⁄₂"
20480U		sm <sup>7</sup> ⁄₀" - sm⁵⁄₀"
20522U		Sf½" - Sf½"
20526U		Sf5⁄8" - Sf5⁄8"
20528U	NIPPLES FEMALE/FEMALE, safety-plus, with turning	sf7/8" - sf7/8"
20530U	сар	sf1" - sf1"
20532U		sf 1¼" - sf 1¼"
20532U		sf 1½" - sf 1½"
20542U		sm½" - F½" - sm½"
20546U	THREADED TEE FEMALE, safety-plus, with PPS	sm‰" - F½" - sm‰"
20550U	NPT thread	sm¼" - F¾" - sm½"
20556U		sm1" - F1" - sm1"

.

20592U	ECCENTRIC THREADED TEE FEMALE, safety- plus, with PPS NPT thread, with spacer brackets	sm½" - F½" - sm½"
20596U		sm⁵‰" - F½" - sm⁵‰"
20662U		sm½" - sm½" - sm½"
20666U		sm⁵ึ∗" - sm⁵ึ∗" - sm⁵ึ∗"
20668U		sm‰" - sm‰" - sm‰"
20670U		sm1" - sm1" - sm1"
20672U	IEE, satety-plus	sm 1¼" - sm 1¼" - sm 1¼"
20674U		sm 1½" - sm 1½" - sm 1½"
20676U		sm 2" - sm 2" - sm 2"
20678U		sm 2½" - sm 2½" - sm 2½"
20717U		sm5⁄8" - sm1⁄2" - sm1⁄2"
20720U		sm⁵‰" - sm½" - sm⁵‰"
20725U		sm½" - sm½" - sm½"
20728U		sm‰" - sm%" - sm%"
20732U		sm1" - sm½" - sm1"
20735U		sm1" - sm⁵‰" - sm1"
20736U		sm1" - sm7⁄₅" - sm1"
20740U	REDUCED TEE, safety-plus	sm1¼"- sm½"- sm1¼"
20742U		sm1¼"- sm⁵⁄₅"- sm1¼"
20744U		sm1¼"- sm½"- sm1¼"
20746U		sm 1¼"- sm 1"- sm 1¼"
20750U		sm1½"- sm½"- sm1½"
20754U		sm1½"- sm⁵⁄₅"- sm1½"
20756U		sm1½"- sm½"- sm1½"

20758U		sm1½"- sm1"- sm1½"
20760U		sm 1½"- sm 1¼"- sm 1½"
20762U		sm 2"- sm1½"- sm 2"
20766U		sm 2"- sm%"- sm 2"
20768U		sm 2"- sm <sup>7</sup> ⁄₅"- sm 2"
20770U		sm 2"- sm1"- sm 2"
20772U		sm 2"- sm1¼"- sm 2"
20774U		sm 2" - sm 1½" - sm 2"
20788U		sm 2½" - sm 2" - sm 2½"
20632U	THREADED T FEMALE ANGLE 90°, safety-plus, with no-lead brass thread and bracket	sf16 - F½"-sf16
20902U		sm½"
20906U		sm⁵⁄₅"
20908U	CLOSING CAP M, safety-plus	sm‰"
20910U		sm1"
20912U		sm 1¼"
20914U		sm 1½"
20916U		sm 2"
20918U		sm 21⁄2"
20952U		sf½"
20956U		sf%"
20958U		sf%"
20960U	CLOSING CAP F, safety-plus	sf1"
20962U		sf 1¼"
20964U		sf 1½"
20966U		sf 2"

20968U		sf 2½"
39102U	CAP, safety-plus, PA-M	1/2"
39106U		5⁄8"
39108U		7⁄8"
39110U		1"
39112U		sf 1¼"
39114U		sf 1½"
39116U		sf 2"
39118U		sf 21⁄2"

# Conditions of Listing:

- 1. Where used in radiant heating systems, the pipe and fittings are recognized for use with water, as well as aqueous solutions of ethylene glycol or propylene glycol for antifreeze, up to 100 percent concentrations of either glycol.
- 2. When installation is in fire-resistance-rated assemblies, evidence of compliance with IBC Section 714 (penetrations) must be provided to the code official for approval.
- 3. During placement of cover over the piping, the pipe must be maintained at the greater of  $1^{1/2}$  times the working pressure or 215 psi (1500 kPa).
- 4. Each installation must be pressure-tested for leaks in the presence of the code official or the code official's designated representative.
- 5. Clearances from heat-producing equipment must be in accordance with the applicable code.
- 6. Hydronic piping systems that utilize a non-potable heat transfer fluid must not be connected to the potable water system except through the use of approved devices such as backflow preventers or double-walled heat exchangers.
- 7. For jurisdictions enforcing the IPC, for water supply and distribution, heat-fusion joints must be installed in accordance with IPC Section 605.20.1.
- 8. Pipe and Fittings recognized in this listing are under a quality control program with surveillance inspections two times per year by ICC-ES.