



CSI: DIVISION: 23 00 00 — MECHANICAL
Section: 23 11 00 — Facility Fuel Piping

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Product: Connectors for Moveable Gas Appliances

Listee: RectorSeal, LLC
2601 Spenwick Drive
Houston, TX 77055
www.rectorseal.com

Compliance with the following codes:

2024, 2021, 2018, 2015, 2012 and 2009 International Fuel Gas Code® (IFGC)
2021, 2018, 2015, 2012 and 2009 International Residential Code® (IRC)
2024, 2021, 2018, 2015, 2012 and 2009 Uniform Plumbing Code (UPC)*

*Uniform Plumbing Code is a copyrighted publication of the International Association of Plumbing and Mechanical Officials

Compliance with the following standard:

ANSI Z21.69/CSA 6.16-2015(R2020), Connectors for Movable Gas Appliances

Identification:

Each connector must be permanently marked, on either a non-removable ring or a portion of a nonremovable fitting not subject to tool usage, on which shall appear the following:

- manufacturer's recognizable trademark, symbol, or name;
- symbol of the organization making the tests for compliance with this Standard;
- a number, not less than 3/32 in (2.4 mm) in height, identical to the last two numbers of the calendar year in which the connector is manufactured, to identify the year of manufacture;
- a letter(s), not less than 3/32 in (2.4 mm) in height, identifying either the month or batch of manufacture. The batch size shall be determined by the manufacturer; and
- a marking to identify "Z21.69 • CSA 6.16."
- the ICC-ES PMG mark of conformity.

Removable end fittings, other than manual valves, or quick disconnect devices or union end pieces, of a connector shall be stamped, etched, or otherwise permanently marked with the connector manufacturer's recognizable trademark or symbol. Manual valves, quick disconnect devices, and three-part unions shall bear the marking of the valve, or device or union manufacturer(s).

Installation:

Connector recognized in this listing shall be installed in accordance with manufacturer's published installation instructions and the applicable codes.

Models:

BIG RED™ gas connectors consists of corrugated stainless steel with SS overbraid flexible hose with PVC coated sleeve are certified for operating pressure of ½ psig.

Brand Name: RectorSeal

<u>Model Number</u>	<u>Description</u>
BR1ODPVC	3/4" ID SS Red PVC Coated Gas Connector (Available in lengths of 36, 48, 60, and 72 inches)

Conditions of Listing:

1. The gas connectors recognized in this listing shall be installed in accordance with manufacturer's installation instructions and applicable codes.
2. The gas connectors are manufactured under a quality control program with annual inspection by ICC-ES.