CSI:      DIVISION: 22 00 00—PLUMBING
          Section:   22 40 00—Plumbing Fixtures (Shower System Kit)

**Product certification system:**

> The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

**Product:**      Ubertile® Waterproofing Products for Tile

**Listee:**      Ubertile a division of Rudiger Group Inc.
          10330-117th Avenue
          Grande Prairie, Alberta, T8V 7S5 Canada
          www.rudiger.ca
          www.ubertile.com

**Compliance with the following codes:**

> 2020, 2015 and 2010 *National Plumbing Code of Canada*® (NPC)*
>
> *\* Copyrighted publication of the National Research Council Canada*

**Compliance with the following standard:**

> ANSI A118.12-2023, Specification for Robinson Floor Test and Crack Isolation Membranes for Thin Set Ceramic Tile and Dimension Stone Installation
> ASTM C666-2015, Test Method for Resistance of Concrete to Rapid Freezing and Thawing
> ASTM E84-2023d, Test Method for Surface Characteristics of Building Materials
> ASTM E331-2000(R23), Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference
> IAPMO PS 106-2015e1, Tileable Shower Receptors and Shower Kits

**Identification:**

> Packaging label for each system shall include the manufacturer's name or trademark as well as the ICC-ES PMG certification mark.

Installation:

The Ubertile® products shall be installed in accordance with the manufacturer's published instructions and the applicable code(s), visit www.ubertile.com website for most up to date installation instructions. Ubertile® products can be cut to size with a utility knife, hand saw or skill saw. Round curvy cuts can be made with a hand saw or jig saw.

Models:

Ubertile® Uberboard and Ubertile® Uberslope products consist of rigid extruded polystyrene foam covered with either a cement or quartz based surface for optimal bonding with modified thinset mortars meeting ANSI A118.4 and/or 118.15 requirements. Ubertile® Tile Backerboards and Shower Pans were proven to be waterproof when tested in accordance with IAPMO PS 106 and ASTM E331. Ubertile® Uberboard Tile Backerboards Material was verified as having no visual defects or cracks when tested to ASTM C666 and the installation is rated "Extra Heavy" when tested to ANSI A118.12 and has a flame-spread rating of 0 and smoke development rating of 70 for a Class A rating when tested in accordance with ASTM E84.

| Series Name | Product Type | Surface Coating | Product Surface |
|---|---|---|---|
| Ubertile® Uberboard | Backerboard, Niche, Curb, Ramp | XPS Foam | Cement & Fibermesh Surface |

| Series Name | Product Type | Surface Coating | Product Surface |
|---|---|---|---|
| Ubertile® Uberslope Point | Presloped Shower Pan | XPS Foam | Quartz version PU |
| **Drain Type:** | Proprietary ABS Drain with 2" and 3" outlet | | |
| **Model Numbers** | | | |
| U-POINT-3260-END | U-POINT-3672-END | U-POINT-4872-CEN | U-POINT-6072-CEN |
| U-POINT-3636-CEN | U-POINT-4444-NEO | U-POINT-4884-CEN | U-POINT-6072-CEN |
| U-POINT-3648-CEN | U-POINT-4848-CEN | U-POINT-4896-CEN | U-POINT-6084-CEN |
| U-POINT-3660-CEN | U-POINT-4848-CNR | U-POINT-6060-CEN | |
| U-POINT-3672-CEN | U-POINT-4860-CEN | U-POINT-6060-CNR | |

| Series Name | Product Type | Surface Coating | Product Surface |
|---|---|---|---|
| Ubertile® Uberslope Thin | Presloped Shower Pan | PET Foam | Quartz version PU |
| **Drain Type:** | Proprietary ABS Drain with 2" and 3" outlet | | |
| **Model Numbers** | | | |
| U-THIN-3660-CEN | U-THIN-4848-CEN | U-THIN-4860-CEN | U-THIN-6060-CEN |

| Series Name | Product Type | Surface Coating | Product Surface |
|---|---|---|---|
| Ubertile® Uberslope Linear | Preslope Shower Pan | XPS Foam | Quartz version PU |
| **Drain Type:** | Proprietary ABS Drain with 2" outlet | | |
| **Model Numbers** | | | |
| U-LINEAR-3648-CEN | U-LINEAR-4848-CEN | U-LINEAR-6048-CEN | U-LINEAR-7848-CEN |
| U-LINEAR-3648-END | U-LINEAR-4848-END | U-LINEAR-6048-END | U-LINEAR-7848-END |

| Series Name | Product Type | Surface Coating | Product Surface |
|---|---|---|---|
| Ubertile® Uberslope Extend | Preslope Shower Pan | XPS Foam | Quartz version Epoxy |
| **Model Numbers** | | | |
| U-EXTEND-2424-CNR | U-EXTEND-2448-STR | U-EXTEND-2496-STR | |
| U-EXTEND-2436-STR | U-EXTEND-2460-STR | | |

Conditions of Listing:

1. The Ubertile® products shall be installed in accordance with the manufacturer's published instructions and the applicable code(s).
2. The Ubertile® products are manufactured under a quality control program with annual surveillance inspections by ICC-ES.